Technical Guide STEICO construction

Construction elements made naturally out of wood

CONTENTS

Products

Properties

- **Applications**
- Design values and span tables
- Detailing
- Connectors
- Insulation
- Safety instructions









CONTENTS

Introdu	ction	4		
I-joists are ideal building elements				
Product overview				
Overvie	w of all I-Joists	8		
Materia	al Properties	9		
Charact	eristic design values to EC5	10		
Permiss	ible design properties to BS 5268 in Service Class 1	12		
Permiss	ible design properties to BS 5268 in Service Class 2	13		
Web stiffeners, backer blocks and connectors				
Rules fo	or service holes	16		
Floors:	Applications	17		
	Span tables for STEICOjoist	18		
	Floor construction details	20		
Roofs:	Applications	27		
	Span tables for STEICOjoist	28		
	Roof construction details	30		
Walls:	Applications	34		
	Axial compression loads for STEICOwall	35		
	Wall construction details	36		
	Thermal insulation	37		
	Fire performance	38		
Genera	l information	39		

ENVIRONMENTALLY FRIENDLY BUILDING PRODUCTS MANUFACTURED FROM SUSTAINABLE RESOURCES

How can we build in an energy efficient, environmentally responsible and sustainable way? This question has fascinated us since the start of our company in 1959, and in asking this we set ourselves a high standard for our products. Stringent tests and voluntary quality checks ensure that our products meet the highest requirements for ecological building and modern methods of construction. Natureplus®, an independent environmental certification organisation, certifies our insulation materials, and we only use raw materials certified by the FSC[®] in our production.



As an insulation specialist we continually work to improve the energy efficiency of buildings and to increase their comfort to the occupier. The STEICO range of products includes products for both timber and masonry structures, for new buildings, refurbishments and renovations. Using STEICO products in a renovation project can increase the energy efficiency of the structure by up to twenty times.

Protecting our environment and the increasing costs of energy are the two main drivers for the continued development of this system, with the production of I-Joists a logical step forward. Lightweight and efficient engineered timber elements combined with high quality insulation materials form the basis for sustainable building and offering both security and comfort for future generations.



Where high quality insulation materials are used, traditional solid wood often poses a technical challenge to designers due to its thermal inefficiency where it acts as a thermal bridge.

Solid timber wall joists or rafters are construction elements that can be inefficient where they act as a thermal bridge. With the STEICOconstruction building system such thermal bridges are reduced to a minimum due to the inherent efficiency of the I-Section profile.

FOLLOWING NATURE'S STEPS: I-JOISTS ARE IDEAL BUILDING ELEMENTS

In nature we find numerous examples of highly efficient structures using a simple principle: where no materials are needed, none are used. The results speak for themselves: consistent performance values, lightweight, low embodied energy and improved energy efficiency in use.

STEICO I-Joists follow these principles and due to their characteristic profile offer the following advantages:



Reduction of thermal bridging



Easy installation of services



Lightweight. Easy to handle and install



Manufactured to standard depths and widths to match industry standards

Available preinsulated to form a solid cross section for ease of installation

High load bearing capacity

High dimensional

stability through controlled moisture

content



Strict manufacturing tolerances



Easy to machine

STEICO*joist* and STEICO*wall* have the following certificates:



The mark of responsible forestry

CE





The STEICOconstruction Building System meets the requirements of:

- The Building Regulations
- NHBC Standards
- ZURICH Insurance
- Robust Details Ltd.



The mark of responsible forestry





| STEICO*joist* **AND STEICO***wall* **ARE NATURAL PRODUCTS**

The production basis for all our joists is timber. Made from slow grown spruce, the flanges are kiln dried and machine stress graded thereby guaranteeing a consistant quality and defined mechanical properties.

The webs are made from structural fibreboard, jointed along the length with a V-groove profile, offering a very high shear capacity. Both the preparation and manufacturing processes of the flanges, the webs and the installation of durable adhesives are carried out using the latest automated assembly lines.

To guarantee a consistently high quality of our products, both internal and external parties control the production process. The I-Joist received a European technical certification from the British Board of Agrément (BBA), ETA-06/0238, and carries the CE-mark.

A unique product is the STEICOwall – available as a pre-insulated stud using natural wood fibres. The spaces between the flanges and the web are pre-insulated thereby eliminating the need to profile the insulation on site, and the stud can therefore be used in the same way as a traditional, solid stud. The insulation materials are made with STEICO's standard quality of natural wood fibres, ensuring excellent thermal conductivity values.



A PRODUCT FOR EVERY APPLICATION



Joists for applications such as floors or roofs.

Special characteristics:

- 8 mm thick structural fibreboard web for high shear capacities
- High quality machine stress graded softwood flange material
- Available as a pre-insulated version





Joists for wall stud applications.

Special characteristics:

- 6 mm thick structural fibreboard web to reduce thermal bridging
- Available as a pre-insulated stud



A perfect match with STEICO insulation materials

The STEICO I-Joists are suitable for use in combination with STEICO insulation materials. Whether wood, hemp or blown loose fibre insulation, fixed or flexible slabs, the complete range of STEICO's ecological insulation materials are available in conjunction with STEICO I-Joists.

For both new building and renovation projects STEICO offers an optimised system enabling highenergy efficiency.

OVERVIEW	OF ALL	I-JOISTS
-----------------	---------------	-----------------



* available in a pre-insulated option

SJ 45



With 8 mm thick structural fibreboard web for high shear applications

SJ 60



F

SJ 90



Properties

MATERIAL PROPERTIES

Matorial	Minimum	Declared thermal conductivity λ_{\perp}	Specific heat capacity	Water vapour diffusion resistance μ acc. to EN 12524	
Material	density ϕ [kg / m ³]	[W/(m*K)] acc. to EN 12524	c [J/(kg*K)] acc. to EN 12524	Dry	Humid
Flange	500	0.13	1600	50	20
Web	900	0.18	1700	10	20

Please note: All STEICO fibreboards are made up of wood fibres aligned in the direction of the mattress. Wood is an anisotropic material with different physical properties along and across the fibres, and with differing properties between the fibreboards and flanges. For an accurate thermal conductivity calculation please use the above value for thermal conductivity, multiplied by 2.2.

Heat transfer per meter [mW]

By using these engineered wood products in40combination with an effective vapour check30and airtight barrier a significant reduction of25heat loss can be achieved. With a temperature20difference of one Kelvin per running meter of15joist the following results can be achieved.10



FIRE PERFORMANCE

STEICO*joist* and STEICO*wall* have fire classifications according to EN 13501-1:2002: D-s2,d0.

Please contact STEICO Ltd. for further fire-test information (01634733220)



| CHARACTERISTIC DESIGN VALUES TO EC5

Characteristic design values to EC5

Refer to page 12 for "Permissible design properties to BS 5268"

Туре	Depth H [mm]	Moment capacity ^{a)} M _{y,k} [kNm]	Flexural rigidity El _{y, mean} [Nmm ² * 10 ⁹]	Shear capacity max V _k [kN]	Shear rigidity GA _{y, mean} [MN]
	200	7.09	327	10.92	2.09
	220	8.00	416	11.85	2.42
	240	8.92	516	12.75	2.76
5145	300	11.74	888	15.36	3.77
	360	14.01	1369	17.84	4.78
	200	9.45	436	10.84	2.09
	220	10.66	554	11.75	2.42
STEICOjoist	240	11.87	687	12.64	2.76
SJ 60	300	15.57	1177	15.17	3.77
	360	18.52	1808	17.55	4.78
	400	20.45	2310	19.07	5.45
	200	14.13	651	10.76	2.09
	220	15.96	827	11.65	2.42
STEICOjoist	240	17.75	1025	12.51	2.76
SJ 90	300	23.21	1752	14.97	3.77
	360	27.51	2683	17.25	4.78
	400	30.30	3419	18.71	5.45
	160	2.49	127	4.50	1.12
STEICOwall	200	3.56	227	5.47	1.63
SW/45	240	4.48	359	6.40	2.13
50045	300	5.90	618	7.72	2.89
	360	7.05	954	8.98	3.64
	160	3.32	169	4.48	1.12
	200	4.74	302	5.43	1.63
STEICOwall	240	5.95	477	6.34	2.13
SW 60	300	7.82	818	7.61	2.89
	360	9.30	1258	8.75	3.64
	400	10.28	1608	8.23	4.15
	240	8.89	711	6.27	2.13
STEICOwall	300	11.64	1216	7.50	2.89
SW 90	360	13.80	1863	8.66	3.64
	400	15.21	2376	8.23	4.15

Characteristic values prepared in accordance with the recommendations of ETAG 011 and BSEN 1995-1-1.

a) The characteristic bending moments are based on the assumption that lateral bracing to the compression flange (at a spacing not exceeding ten times the flange width) is in place.

Characteristic bearing values to EC5

Refer to page 15 for web stiffener installation details

			End bearing [kN]				bearing [kN]
Turne	Durath II	Bearing ler	ngth 45 mm	Bearing ler	ngth 90 mm	Bearing ler	igth 90 mm
туре	Берши	Web st	iffener	Web st	tiffener	Web stiffener	
		no	yes	no	yes	no	yes
	200		9.7		10.7		16.1
STEICOinist	220		10.0		11.0		16.4
STEICOJOISE	240	8.1	10.3	8.7	11.3	16.0	16.7
5145	300		11.2		12.2		17.6
	360		12.1]	13.1		18.5
	200	12.0	12.7	12.6	14.2	21.6	23.0
	220		13.0		14.5		23.3
STEICO <i>joist</i>	240		13.3		14.8		23.6
SJ 60	300		14.2		15.7		24.5
	360		15.1		16.6		25.4
	400		15.7		17.2		26.0
	200		13.8		15.4	_	35.9
	220		14.1		15.7		36.2
STEICOjoist	240	12.0	14.4	15.2	16.0	20.2	36.5
S1 90	300	12.9	15.3	- 15.3	16.9	29.3	37.4
	360]	16.2		17.8		38.2
	400		16.8		18.4		38.9

Values of k_{mod} to be used with EC 5 when designing STEICO I-joist products

Duration of load	Bending and axial resistance		Shear re	sistance	Bearing resistance	
	Service class 1	Service class 2	Service class 1	Service class 2	Service class 1	Service class 2
Permanent	0.60	0.60	0.30	0.20	0.60	0.60
Long term	0.70	0.70	0.45	0.30	0.70	0.70
Medium term	0.80	0.80	0.65	0.45	0.80	0.80
Short term	0.90	0.90	0.85	0.60	0.90	0.90
Instantaneous	1.10	1.10	1.10	0.80	1.10	1.10

 γ_m can be taken as 1.3 in general

| PERMISSIBLE DESIGN PROPERTIES TO BS 5268 FOR STEICOjoist IN SERVICE CLASS 1

Туре	Depth H [mm]	Moment ^{a)} [kNm]	Bending rigidity [Nmm ² *10 ⁹]	Shear [kN]	Shear rigidity [MN]
	200	2.73	327	2.70	1.25
	220	3.08	416	2.93	1.45
	240	3.43	516	3.15	1.66
3145	300	4.52	888	3.79	2.26
	360	5.40	1369	4.41	2.87
	200	3.64	436	2.68	1.25
	220	4.10	554	2.90	1.45
STEICOjoist	240	4.57	687	3.12	1.66
SJ 60	300	6.00	1177	3.75	2.26
	360	7.13	1808	4.33	2.87
	400	7.87	2310	4.71	3.27
	200	5.44	651	2.66	1.25
	220	6.14	827	2.88	1.45
STEICOjoist	240	6.83	1025	3.09	1.66
SJ 90	300	8.94	1752	3.70	2.26
	360	10.59	2683	4.26	2.87
	400	11.67	3419	4.62	3.27

Design values for Service Class 1

^{a)} The characteristic bending moments are based on the assumption that lateral bracing to the compression flange (at a spacing not exceeding ten times the flange width) is in place.

BS 5268 bearing values for Service Class 1

Refer to page 15 for web stiffener installation details

			End bea		Intermediate bearing [kN]			
-	Danath II	Bearing ler	Bearing length 45 mm Web stiffener		Bearing length 90 mm		Bearing length 90 mm	
туре	Depth H	Web st			tiffener	Web stiffener		
		no	yes	no	yes	no	yes	
	200		3.73		4.12		6.20	
STEICOioist	220		3.85		4.24		6.31	
	240	3.12	3.97	3.35	4.35	6.16	6.43	
5145	300		4.31		4.70		6.78	
	360		4.66		5.04		7.12	
	200	4.62	4.89	4.85	5.47	8.32	8.86	
	220		5.01		5.58		8.97	
STEICOjoist	240		5.12		5.70		9.09	
SJ 60	300		5.47		6.04		9.43	
	360		5.81		6.39		9.78	
	400		6.04		6.62		10.01	
	200		5.31		5.93	- 11.28	13.82	
	220		5.43		6.04		13.94	
STEICOjoist	240	4.07	5.54		6.16		14.05	
SJ 90	300	4.97	5.89	5.89	6.51		14.40	
	360		6.24]	6.85		14.75	
	400		6.47		7.08		14.98	

Notes: please refer to page 14.

PERMISSIBLE DESIGN PROPERTIES TO BS 5268 FOR STEICOjoist IN SERVICE CLASS 2

Туре	Depth H [mm]	Moment ^{a)} [kNm]	Bending rigidity [Nmm ² *10 ⁹]	Shear [kN]	Shear rigidity [MN]
	200	2.73	303	1.80	1.06
STEICOloist	220	3.08	386	1.95	1.23
	240	3.43	479	2.10	1.41
5145	300	4.52	823	2.53	1.92
	360	5.40	1269	2.94	2.43
	200	3.64	404	1.79	1.06
	220	4.10	513	1.94	1.23
STEICOjoist	240	4.57	636	2.08	1.41
SJ 60	300	6.00	1091	2.50	1.92
	360	7.13	1676	2.89	2.43
	400	7.87	2141	3.14	2.78
	200	5.44	604	1.77	1.06
	220	6.14	767	1.92	1.23
STEICOjoist	240	6.83	950	2.06	1.41
SJ 90	300	8.94	1624	2.46	1.92
	360	10.59	2487	2.84	2.43
	400	11.67	3169	3.08	2.78

Design values for Service Class 2

^{a)} The characteristic bending moments are based on the assumption that lateral bracing to compression flange (at a spacing not exceeding ten times the flange width) is in place.

BS 5268 values for Service Class 2

Refer to page 15 for web stiffener installation details

			End bea		Intermediate bearing [kN] Bearing length 90 mm		
T	Danath II	Bearing ler	Bearing length 45 mm				ngth 90 mm
туре	Depth H	Web st	iffener	Web st	iffener	Web stiffener	
		no	yes	no	yes	no	yes
	200		3.73		4.12		6.20
STEICOinist	220		3.85		4.24		6.31
STEICOJOISE	240	3.12	3.97	3.35	4.35	6.16	6.43
5145	300		4.31		4.70		6.78
	360		4.66		5.04		7.12
	200		4.89	- 4.85	5.47	8.32	8.86
	220		5.01		5.58		8.97
STEICOjoist	240		5.12		5.70		9.09
SJ 60	300	4.02	5.47		6.04		9.43
	360		5.81		6.39		9.78
	400		6.04		6.62		10.01
	200		5.31		5.93	11.28	13.82
	220		5.43		6.04		13.94
STEICOjoist	240	4.07	5.54		6.16		14.05
SJ 90	300	4.97	5.89	5.89	6.51		14.40
	360		6.24]	6.85		14.75
	400		6.47		7.08		14.98

Notes: please refer to page 14.

PERMISSIBLE DESIGN PROPERTIES TO BS 5268 FOR STEICOwall IN SERVICE CLASS 2

Туре	Depth H [mm]	Moment ^{a)} [kNm]	Bending rigidity [Nmm ² *10 ⁹]	Shear [kN]	Shear rigidity [MN]
	160	0.96	118	0.74	0.57
STELCOWOLL	200	1.37	211	0.90	0.83
STEICOWAII	240	1.72	333	1.05	1.09
500 45	300	2.27	573	1.27	1.47
	360	2.72	884	1.48	1.86
	160	1.28	157	0.74	0.57
	200	1.82	280	0.89	0.83
STEICOwall	240	2.29	442	1.04	1.09
SW 60	300	3.01	758	1.25	1.47
	360	3.58	1166	1.44	1.86
	400	3.96	1490	1.36	2.11
	240	3.42	659	1.03	1.09
STEICOwall	300	4.48	1127	1.24	1.47
SW 90	360	5.31	1727	1.43	1.86
	400	5.86	2202	1.36	2.11

Design values STEICOwall to BS 5268 – Service Class II

a) The characteristic bending moments are based on the assumption that lateral bracing to compression flange (at a spacing not exceeding ten times the flange width) is in place.

Notes:

- Values shown are for non-loadsharing conditions. Where the joist centres are < 610 mm a load-sharing factor K₃ of 1,10 should be applied to the permissible moment, shear and bearing values in accordance with BS 5268.
- A $K_{\rm dom}$ factor of 1.12 can be adopted when designing residential floors within self contained dwellings where the

imposed load is no greater than $1,5 kN/m^2.$ This is applicable to the permissible moment, shear and bearing values.

• Data shown is taken from characteristic values, page 10.

STEICOjoist SJ 90

WEB STIFFENERS AND BACKER BLOCKS

In certain conditions or construction solutions web stiffeners are required. Web stiffeners are used specifically to increase the load capacity of intermediate and end bearings, to allow high point loads and to laterally support the top flange of the joist for some hanger applications.

Backer blocks may be required where hangers are fitted to I-joists. Please refer to detail G4, G5, R11 and the hanger manufacturers literature for further information.



STEICOjoist SJ 60



Installation of Web Stiffeners and Backer Blocks:

- For enhanced bearings, all pitched hangers, birdsmouth cut locations and where hangers do not restrain the top flange, web stiffeners must be fitted so that they are tight to the bottom flange and there is a 5-10 mm gap between the stiffeners and the top flange.
- Where concentrated point loads are applied onto the top flange, web stiffeners must be fitted so that they are tight to the top flange, leaving a 5-10 mm gap between the stiffeners and the bottom flange.

Backer Block & Web Stiffener table

	STEICOjoist					
Depth	SJ45	SJ60	S190			
200	19 * 105 mm	24 * 105 mm	38 * 105 mm			
220	19 * 125 mm	24 * 125 mm	38 * 125 mm			
240	19 * 145 mm	24 * 145 mm	38 * 145 mm			
300	19 * 205 mm	24 * 205 mm	38 * 205 mm			
360	19 * 265 mm	24 * 265 mm	38 * 265 mm			
400	19 * 305 mm	24 * 305 mm	38 * 305 mm			

All Backer blocks to be minimum 250 mm wide. All web stiffeners to be minimum 100 mm wide. Use solid timber, OSB 3 or structural ply to BS 5268

For connectors please contact:

SIMPSON Simpson Strong-Tie® Winchester Road Strong-Tie **Cardinal Point Tamworth** Staffordshire B78 3HG Tel.: 01827 255600 Fax: 01827 255616 www.strongtie.co.uk

Cullen Building Products 1 Wheatstone Place Southfield Industrial Estate Glenrothes Fife KY6 2SW Tel.: 01592 771132 Fax: 01592 771182 www.cullen-bp.com



Gap 5 - 10 mm

Web stiffeners

Fixing with nails

made from

structurally graded timber

3.35 * 90 mm

For web stiffener applications, please refer to Floor and Roof Construction Details

ACCESS AND SERVICE HOLES

Holes should be positioned in the middle of the web. The location and maximum sizes of the holes can be calculated in accordance with the drawing and table below.

Holes up to a maximum diameter of 20 mm can be made in any part of the web, as long as the distance between the hole edges is a minimum of 40 mm. For other hole diameters please refer to the table below.



Joist depth	200 mm	200 mm 220 mm 240 mm 300 mm		300 mm	360 mm	400 mm				
Minimum distance to bearing or point load F	200 mm	220 mm	240 mm	300 mm	360 mm	400 mm				
Minimum distance between two holes		2 * diameter of largest hole								
Maximum diameter D	100 mm	120 mm	140 mm	200 mm	200 mm	200 mm				

Note: For holes with a diameter greater than 20 mm please refer to the STEICO European Technical Approval ETA-06/0238 for information on calculating the reduction in the characteristic shear value of the joist. Where holes are required in trimmers, headers, beams or joists which are not uniformly loaded please contact your floor designer or engineer. Holes which do not meet the requirements of the above hole chart may be checked by the floor designer using our design software. Please contact STEICO technical support for further information on 01634733220.

INCORRECT HANDLING AND HOLES

- Notches and holes in the flanges are not allowed
- Holes have to be drilled
- Rectangular holes are not allowed



Floors

FLOOR APPLICATIONS



Engineers have long recognised the advantages of an I section in structural elements. Suitable material is only used in those places where it meets the needs, resulting in a slender and economical building element for floors, walls and roofs.

Modern structures require high performance and cost efficient constructions in which shrinkage and movement are a thing of the past. The carefully selected components used in the flange and web create a high quality engineered wood product, designed to reduce movement and other problems associated with solid timber floors.

Thanks to its engineered properties the STEICO*joist* is dimensionally stable, avoiding the need for mid span blocking to be installed and reduces the risk of nail popping in plasterboard caused by timber shrinkage.

Due to its light-weight properties, new floors are easily incorporated into renovation projects where access is limited and handling issues are important.

SPAN TABLES FOR STEICOjoist TO BS 5268



Maximum single spans I in [m], max. deflection = 12 mm or 0,003 * I

Live load Q=1,5 kN/m²

Туре	Depth H [mm]		G=0,75 kN/m ² Joist centers [mm]		G=1,25 kN/m ² Joist centers [mm]				
		400	480	600	400	480	600		
	200	4.13	3.92	3.60	3.89	3.64	3.34		
STELCO in ist	220	4.39	4.19	3.92	4.16	3.95	3.64		
STEICOJOIST	240	4.64	4.42	4.16	4.40	4.19	3.92		
5145	300	5.32	5.07	4.78	5.05	4.80	4.52		
	360	5.93	5.65	5.33	5.63	5.36	4.66		
	200	4.42	4.21	3.94	4.18	3.98	3.65		
	220	4.70	4.47	4.21	4.45	4.23	3.98		
STEICOjoist	240	4.96	4.72	4.44	4.70	4.47	4.21		
SJ 60	300	5.68	5.41	5.09	5.39	5.13	4.82		
	360	6.33	6.03	5.68	6.00	5.71	5.38		
	400	6.73	6.41	6.04	6.38	6.08	5.72		
	200	4.84	4.61	4.33	4.58	4.36	3.97		
	220	5.15	4.90	4.60	4.87	4.63	4.30		
STEICOjoist	240	5.44	5.17	4.86	5.15	4.89	4.60		
SJ 90	300	6.23	5.93	5.57	5.90	5.61	5.27		
	360	6.94	6.60	6.21	6.57	6.25	5.87		
	400	7.37	7.02	6.60	6.98	6.64	6.24		



Live load Q=1,5 kN/m²

max. deflection = 12 mm or 0,003 * l G=0,75 kN/m² Joist centers [mm]

Maximum double spans with mid span support I in [m],

Туре	Depth H [mm]		G=0,75 kN/m ² Joist centers [mm]		G=1,25 kN/m ² Joist centers [mm]				
		400	480	600	400	480	600		
	200	4.70	4.47	4.21	4.52	4.30	3.61		
	220	4.99	4.76	4.48	4.80	4.58	3.68		
	240	5.27	5.02	4.50	5.08	4.60	3.68		
3145	300	6.04	5.62	4.50	5.52	4.60	3.68		
	360	6.74	5.62	4.50	5.52	4.60	3.68		
	200	5.02	4.78	4.30	4.83	4.39	3.59		
	220	5.34	5.08	4.66	5.13	4.76	3.89		
STEICO <i>joist</i>	240	5.64	5.37	5.01	5.42	5.12	4.19		
SJ 60	300	6.46	6.15	5.79	6.21	5.92	4.97		
	360	7.19	6.85	6.07	6.92	6.21	4.97		
	400	7.65	7.29	6.07	7.36	6.21	4.97		
	200	5.51	5.24	4.27	5.15	4.36	3.57		
	220	5.86	5.57	4.63	5.58	4.72	3.86		
STEICO <i>joist</i>	240	6.18	5.88	4.97	5.95	5.07	4.15		
SJ 90	300	7.08	6.74	5.95	6.81	6.07	4.97		
	360	7.89	7.51	6.87	7.58	7.01	5.72		
	400	8.38	7.98	7.46	8.06	7.61	6.23		

General comments:

- These tables serve as a guide only and do not replace independent structural calculations prepared by a qualified structural engineer.
- Please pay special attention to the bearing conditions.
- Do not use these tables to calculate point or irregular loads.
- Spans indicated are between centres of supports.
- Q = design imposed loads. G= design dead loads. The UKTFA Engineered Wood Products Committee recommends a minimum dead load for single occupancy domestic floors of 0.41 kN/m² plus an allowance of 0.22 kN/2 for non-loadbearing partitions (up to 27 kg/m²), irrespective of whether

they are present on the floor. Where partition positions are known, the final design should reflect the worst case of either the blanket UDL (incl partitions) or the dead load plus a minimum line load of 0.64 kN/m at partition locations. Where the calculated dead loads exceed the recommended minimum (ie: compartment floors and multi-boarded partitions), these must be adopted.

- Dead loads (G) include the self weight of the joists.
- Span tables are for floor joists under service class 1 conditions only.

| FLOOR CONSTRUCTION DETAILS



NOTES TO THE DETAILS

Bearing lengths

- End bearing minimum 45 mm
- Intermediate bearing minimum 90 mm

Fastening

- Where bearing onto an external timber frame wall, STEICO*joists* must be secured to a Glulam (e.g. Panelam) rim board, a rim joist or other suitable EWP using nails or suitable hangers.
- STEICO*joists* to be nailed to head plates using minimum 2 No. 3.35 * 90 ring shank nails, located a minimum of 38 mm from the end of the joist. Nails may need to be skewed slightly to avoid splitting the bearing plate.
- Where required, compression blocks are to be fixed to each flange using a minimum of one 3.35 dia nail. Ensure the block is cut from graded timber or an EWP to the same depth as the joist.
- The typical details shown are for guidance only and should be used in conjunction with the recommendations and requirements of the UKTFA, British Standards, NHBC, Zurich, Robust Details Ltd, Building regulations and all other statutory bodies.



TIMBER FRAME FLOOR CONSTRUCTION DETAILS



MASONRY DETAILS

M1 Bearing onto blockwork cavity wall

All joists to have a minimum bearing of 90 mm. Ensure all bearings are flat, level an that the joists are vertical.

Minimum 38 * 38 perimeter noggin skew nailed or fixed to joist using proprietry clip. noggin to be fixed 25-75 mm from face of wall.

Web stiffeners fitted to end of joists. Junction between wall and joists to be sealed with silicon mastic.

Restraint straps may be required for buildings over 2 storeys or where joists have less than 90 mm of bearing. Please consult hanger manufacturers literature for further information

M2b Bearing onto blockwork cavity wall using proprietary end stopper

Proprietary end stopper system



Minimum 38 * 38 perimeter noggin skew nailed or fixed to joist using propriety clip. Noggin to be fixed 25 - 75 mm from face of wall

Ensure all bearings are flat, level and that the joists are vertical. Please refer to manufactureres details for full installation details and restraint strap requirements.



M2a Bearing onto blockwork cavity wall using proprietary seal



Please refer to manufactureres details for full installation details and restraint strap requirements.



specification and installation details

MASONRY DETAILS



GENERAL DETAILS







G4 STEICOjoist to STEICOjoist connection



Install Backer blocks on both sides of STEICO*joist*. Attach with 10 no. 3.75 * 75 nails, clenched where possible. Backer block to be a minimum of 250 mm wide.

Install Backer blocks tight to top flange for top mount hangers and tight to bottom flange for face mount hangers.

Please refer to hanger manufacturers literature for alternative hanger options.





GROUND FLOOR DETAILS

Joists to be designed to service class 2







Roofs

ROOF APPLICATIONS



Highly insulated roof constructions are easily achieved with the STEICO*joist*. The light-weight joist provides the user a fast and efficient installation for which your carpenter will thank you.

| SPAN TABLES FOR STEICOjoist TO BS 5268

Single span max. deflection = 0,003 * l

Deel load Q

www.imposed load Q

Maximum single spans I in [m]

Imposed load $Q = 0,75 \text{ kN}/\text{m}^2$

		$0,5 \text{ kN} / \text{m}^2 < \text{G} \le 0,75 \text{ kN} / ^2$						$0,75 \text{kN}/\text{m}^2 < \text{G} \le 1,0 \text{kN}/^2$					
Turne	5 (1) (T 1	α<	5°	5° ≤α	< 30°	30 °≤c	×45°	α<	5°	5° ≤α	< 30°	30 °≤ a	<45°
туре		Joist cent	ers [mm]	Joist cent	ters [mm]	Joist cent	ers [mm]	Joist cent	ers [mm]	Joist cent	ers [mm]	Joist cent	ers [mm]
		400	600	400	600	400	600	400	600	400	600	400	600
	200	4.83	4.18	4.52	3.92	4.09	3.55	4.57	3.95	4.27	3.69	3.84	3.33
	220	5.25	4.54	4.91	4.25	4.44	3.85	4.97	4.29	4.63	4.01	4.17	3.62
SLAF	240	5.65	4.89	5.29	4.58	4.78	4.15	5.35	4.63	4.99	4.32	4.49	3.89
3145	300	6.80	5.89	6.35	5.51	5.74	4.99	6.44	5.57	6.00	5.20	5.40	4.68
	350	7.70	6.67	7.19	6.24	6.50	5.64	7.29	6.32	6.79	5.89	6.11	5.30
	200	5.30	4.58	4.96	4.29	4.49	3.89	5.01	4.32	4.68	4.04	4.22	3.65
	220	5.76	4.97	5.39	4.66	4.87	4.22	5.45	4.70	5.08	4.39	4.58	3.96
STEICOjoist	240	6.20	5.36	5.80	5.02	5.24	4.55	5.86	5.06	5.47	4.73	4.93	4.27
SJ 60	300	7.45	6.45	6.96	6.04	6.29	5.46	7.05	6.10	6.57	5.69	5.91	5.13
	350	8.42	7.30	7.88	6.83	7.12	6.18	7.98	6.91	7.44	6.44	6.69	5.80
	400	9.36	8.11	8.75	7.59	7.90	6.86	8.87	7.68	8.26	7.16	7.43	6.45
	200	6.03	5.20	5.65	4.88	5.12	4.43	5.70	4.90	5.32	4.59	4.80	4.15
	220	6.55	5.65	6.13	5.30	5.55	4.81	6.19	5.33	5.78	4.99	5.21	4.51
STEICOjoist	240	7.05	6.08	6.60	5.71	5.97	5.17	6.67	5.75	6.22	5.37	5.61	4.85
SJ 90	300	8.47	7.32	7.92	6.86	7.16	6.21	8.01	6.92	7.47	6.46	6.73	5.83
	350	9.57	8.28	8.95	7.76	8.10	7.02	9.06	7.83	8.45	7.31	7.61	6.60
	400	10.63	9.20	9.94	8.62	8.98	7.80	10.06	8.71	9.38	8.12	8.44	7.32

Double span max. deflection = 0,003 * l

Maximum double spans I in [m]

Imposed load $Q = 0.75 \text{ kN}/\text{m}^2$

		$0,5 \text{ kN}/\text{m}^2 < \text{G} \le 0,75 \text{ kN}/^2$							$0,75 kN / m^2 < G \le 1,0 kN / ^2$					
T	Danth II (mm)	α<	: 5°	5° ≤α	< 30°	30 °≤ 0	a < 45°	α<	: 5°	5° ≤α	< 30°	30 °≤0	د<45°	
туре	Depth H [mm]	Joist cent	ters [mm]	Joist cent	Joist centers [mm]		Joist centers [mm]		ters [mm]	Joist centers [mm]		Joist centers [mm]		
		400	600	400	600	400	600	400	600	400	600	400	600	
	200	6.03	5.26	5.66	4.93	5.14	4.49	5.80	5.06	5.42	4.73	4.91	4.28	
	220	6.53	5.70	6.13	5.35	5.57	4.86	6.29	5.48	5.88	5.13	5.32	4.64	
STEICOJOIST	240	7.02	6.13	6.59	5.75	5.99	5.23	6.76	5.89	6.32	5.51	5.72	4.99	
5145	300	8.42	7.35	7.90	6.89	7.18	6.27	8.10	6.46	7.58	6.33	6.85	5.82	
	350	9.52	7.54	8.93	7.40	8.11	6.84	9.02	6.46	8.39	6.79	7.72	6.22	
	200	6.63	5.78	6.22	5.42	5.66	4.93	6.38	5.56	5.97	5.20	5.40	4.71	
	220	7.18	6.26	6.74	5.88	6.13	5.35	6.91	6.03	6.46	5.64	5.85	5.10	
STEICOjoist	240	7.72	6.73	7.24	6.32	6.58	5.75	7.43	6.48	6.95	6.06	6.28	5.48	
SJ 60	300	9.25	8.06	8.67	7.57	7.88	6.88	8.89	7.76	8.32	7.26	7.52	6.57	
	350	10.44	9.11	9.79	8.55	8.90	7.77	10.04	8.46	9.39	7.86	8.49	7.23	
	400	11.58	9.73	10.87	9.08	9.88	8.41	11.04	8.73	10.29	8.34	9.42	7.65	
	200	7.57	6.60	7.11	6.20	6.46	5.64	7.29	5.97	6.82	5.94	6.17	5.38	
	220	8.20	7.15	7.70	6.71	7.00	6.11	7.89	6.46	7.38	6.44	6.68	5.83	
STEICOjoist	240	8.81	7.68	8.27	7.21	7.52	6.56	8.48	6.94	7.93	6.92	7.18	6.26	
SJ 90	300	10.55	9.20	9.90	8.63	9.00	7.85	10.15	8.31	9.49	8.28	8.59	7.49	
	350	11.90	10.38	11.17	9.74	10.15	8.86	11.45	9.38	10.71	9.34	9.69	8.45	
	400	13.19	11.51	12.38	10.80	11.25	9.82	12.69	10.41	11.87	10.23	10.73	9.37	

SPAN TABLES FOR STEICO*joist*

Different roof constructions require varying dead loads and pitches from 5 degrees upwards. In the tables these dead loads are summarised, with a difference made for light roofs (e.g. sheeting roofs) and heavier roofs (e.g. tiled roofs) and guidance on pitches between 5 degrees up to 45 degrees.

General comments:

- These tables serve as a guide only and do not replace independent structural calculations prepared by a qualified structural engineer.
- Please pay special attention to the bearing conditions.
- Do not use these tables to calculate point or irregular loads.
- Spans indicated are between centres of supports.
- Calculations are based on BS 5268.
- Lateral bracing is required to the flange at a spacing not exceeding ten times the flange width.
- Q = design imposed loads on plan. G = design dead loads acting perpendicular with the roof slope. Imposed loads are from BS6399-3 clause 4.3.2 for small buildings. Dead loads will vary for differing roof finishes and manufacturers technical literature should be consulted to ensure adequate allowance is made when assessing the design dead load.
- Span tables are for roof joists under service class 1 conditions only and assume continuous lateral restraint is provided to the top flange from either tiling battens combined with suitable diagonal bracing or from a sheathing board. Where load reversal due to wind uplift is probable, suitable restraint from sheathing of plasterboard must be provided to the bottom flange.

ROOF CONSTRUCTION DETAILS



NOTES TO THE DETAILS

Bearing lengths

- A minimum end bearing of 45 mm is required
- Intermediate bearing minimum 90 mm

Fastening

- STEICO*joist* to be nailed to head plates using a minimum of 2 No. 3.35 * 90 ring shank nails, located a minimum of 38 mm from the end of the joist. Nails may need to be skewed slightly to avoid splitting the bearing plate. For roofs pitched > 25 degrees, lateral forces may be significant and additional fixings to prevent roof spread may be required.
- Typical details shown are for guidance only and should be used in conjunction with the recommendations and requirements of the UKTFA, British Standards, NHBC, Zurich, Robust Details Ltd, Building regulations and all other statutory bodies.

Web stiffeners

- Web stiffeners are required for birdsmouth cuts and should be independently verified by a suitably qualified structural engineer.
- Web stiffeners should be applied where the sides of the hanger do not laterally support the top flange of the joist.

Blocking

 Blocking to provide lateral restraint must be installed at bearings. Blocking can be from EWP such as glulam or STEICOjoist.

Cantilevers

• Cantilevers should be restricted to a maximum of 750 mm past the centre of the bearing to the end of the joist. Ensure that blocking is installed at the bearing and that the top and bottom flanges are restrained by sheathing.



| ROOF CONSTRUCTION DETAILS



Gable ladder fixed to top

R9b Gable ladder





LVL/Glulam trimmer or STEICOjoist



Do not cut the flange. Restraint strap from an approved connector supplier; install as per manufacturer's instructions.



Walls

WALL APPLICATIONS



STEICOwall is a slender, efficient building element for wall constructions that demand a high level of both energy efficiency and strength. Using pre-insulated STEICOwall studs facilitates easy insulation of the structure and thereby contributes to overall cost savings.

CHARACTERISTIC AXIAL COMPRESSION LOADS FOR STEICO*wall* TO EC 5

Туре	Flange b*h [mm]	With one side only sheathed ^{a)} N _k [kN]	With both sides sheathed ^{a)} N _k [kN]
STEICO <i>wall</i> SW 45	45*45	6.1	55.5
STEICO <i>wall</i> SW 60	60*45	14.2	74.9
STEICO <i>wall</i> SW 90	90*45	45.0	124.9

Note: The above tables are based on a wall panel height of 2,5 m.

Sheathing to the requirements of BS 5268 to provide lateral restraint to the flanges and it is recommended that in all construction this is provided to both sides of the stud. Where the studs are part of a system offering lateral restraint to a structure, a minimum of 1 layer of category 1 or 2 sheathing must be provided. Where wind reversal occurs, both faces must be sheathed to prevent buckling.

CHARACTERISTIC LOAD ON THE SUPPORT ACCORDING TO EC5 FOR SOLID TIMBER C16, C24 AND GLULAM GL28^{b)}

Type	Flange				Characterist	istic load per stud in kN ^{a)}					
b b	b * h [mm]	C 16	C 24	GL 28	C 16	C 24	GL 28	C 16	C 24	GL28	
STEICO <i>wall</i> SW 45	45 * 45	25.1	28.5	30.8	22.5	25.6	27.6	22.5	25.6	27.6	
STEICO <i>wall</i> SW 60	60 * 45	30.9	35.1	37.9	28.3	32.2	34.7	28.3	32.2	34.7	
STEICO <i>wall</i> SW 90	90 * 45	41.3	47.0	50.7	38.8	44.0	47.6	38.8	44.0	47.6	

a) The design values have to be calculated in the following way:

 N_d = N_k * k_{mod}/γ_m where: N_k ${\triangleq}$ tabular value, k_{mod} ${\triangleq}$ modification factor,

 $\gamma_{m} \triangleq partial \ factor \ for \ material \ properties$

b) For sole plate/top plate of 43 mm height

Calculation Assumptions:

- Load discharge takes place in the middle of the joist
- Even load distribution on both flanges

WALL CONSTRUCTION DETAILS













THERMAL INSULATION

With its I-section profile, the STEICOwall is ideally suited for wall constructions with high thermal requirements. Low energy buildings may be efficiently constructed.

The factory-made flange filler insulation and bespoke insulation widths of the STEICO*wall* allow energy efficient design and the easy installation of the STEICO flexible insulation products.

| WALL CONSTRUCTIONS





Thermal performance

Solid timber stud

- 1 Plasterboard 12.5 mm
- 2 Vapour barrier
- 3 A STEICO*wall* 45/160 B Solid stud 38/140
- 4 A STEICOflex 160 mm B Mineral wool 140 mm
- 5 OSB 9 mm
- 6 Breather paper

Version	Overall U-Value	Phase shift
Construction A	0.238	8.3
Construction B	0.284	5.6



FIRE PROTECTION

STEICO products are suitable for use in wall constructions requiring fire protection. Wood and wood based products in conjunction with fire resistant materials provide positive fire protection properties with a measurable char rating.

Wall construction F 30-B

According to the general building code test certificate "AbP P-SAC 02/ III-201" from STEICO AG.

A) Wall construction with timber cladding

- Timber cladding $d \ge 20 \text{ mm}$ 1
- Battens and cross battens $\geq 50\,mm$ 2
 - STEICOuniversal 35 or 52 mm 3
 - STEICOwal/ 160-360
 - Stud centers 400-600 mm 4
 - STEICO*flex* \ge 160 mm 5
 - Wood based panel \geq 15 mm 6
 - Plasterboard 12.5 mm 7



B) Wall construction with rendered finish

- Render system $d \ge 4 \text{ mm}$ 1
- STEICO*protect* render board $d \ge 40 \text{ mm}$ 2
 - STEICOwall 160-360 3
 - Stud centers 400 600 mm
 - STEICO*flex* \geq 160 mm 4
 - Wood based panel \geq 15 mm 5
 - Fermacell gypsumboard $d \ge 15 \text{ mm}$ 6



Additional construction alternatives are possible. Please contact your STEICO partner for more information.

General information

Proper erection procedures and the installation of bracing are essential to safe construction when using I-joists. The following notes may assist builders when preparing safety assessments under the CDM regulations 1994.

INSTALLATION NOTES (IN ACCORDANCE TO UKTFA-GUIDANCE)



- Under no circumstances walk on joists until they are fully braced.
- Do not store building materials on unbraced joists.
- I-joists are unstable until fully braced. This includes temporary and permanent longtitudinal and diagonal bracing, rim boards/joists, stability blocking.
- Temporary bracing to be installed as per UKTFAguidance.
- Temporary bracing may be progressively removed as decking proceeds, leaving bracing in place on un-decked areas.



- Construction materials may only be placed on joists when all bracing is in place. Materials should be positioned so they are spread over at least 4 joists and no more than 1.5 m from a support. Floor/ceiling boards may only be stacked up to a height of 250 mm (150 kg per joist at 600 centres, 100 kg per joist at 400 centres).
- Flooring should be fully fixed to the joists in accordance with manufacturers recommendations before additional loads are placed on the system.
- STEICO AG do not currently recommend the use of "no-nails" decking solutions to be used in conjunction with their products.
- Under no circumstances use damaged joists or attempt to repair them.

STORAGE NOTES

- STEICO Joists must be stored straight and vertical.
- STEICO joists should be stored vertically, on level bearers, at least 150 mm high and spaced at approx 3.0 m centres.
- Leave banding in place until the joists are ready for use.
- When stored, protect joists at all times from direct weather exposure with an appropriate covering.
- Always lift the joists using the bottom flange.



Reduction of thermal bridging

Easy installation of services



Manufactured to standard depths and to match standard connectors



Available preinsulated to form a solid cross section for ease of installation



Easy to machine







ABOUT STEICO

STEICO operates worldwide with

approx. 900 employees. Steico Limited

Along with I-Joists STEICO manufactures

operates from offices in Harpenden, Bedfordshire and Rochester, Kent.

a huge product range of insulation

hemp at three modern

production facilities .

level for the products.

CE

materials made from wood fibres and

Ongoing Quality Control in our own

laboratories as well as independent

The STEICO production is certified according to ISO 9001:2000.

Quality Control by recognised European

institutions, guarantees a high quality

Lightweight. Easy to handle and install



High dimensional stability through controlled moisture content



High load bearing

capacity

...........

Strict manufacturing tolerances



European Techncal Approval ETA-06/0238 BBA BRITISH BOARD OF AGREMENT



Operating site certified according to ISO 9001:2000

lixed Sources
ŝ

Printed on FSC $^{\odot}$ certified paper. Date 01/2009. Valid subject to subsequent revisions and technical changes



Your STEICO Partner

www.steico.com